

LOCATION 421 S. Columbia St. CITY Garfield  
BETWEEN Maple STREET & 5th STREET

	SIZE	TYPE	LENGTH	INSTALLED	<del>RETIRED</del>	<del>RENEWED</del>
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>8793</u>	<u>Tied on</u>	<u>65 of 3/4</u>
MAIN TO PROP. LINE					<u>cur ser. to</u>	<u>Ext 2" Plastic</u>
PROP. LINE TO BLDG.					<u>main</u>	

ENTERS: 421 BRANCHED INTO: 419

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 12' w of Co of Columbia  
109' w of Co of Maple


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 24 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1\* 2 17\* 2 L.R. # \_\_\_\_\_

REMARKS: Trace wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>103</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY