

LOCATION 429 S Columbin st CITY GASTONIA
 BETWEEN 5th Ave STREET & MAPLE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	CW Plastic	79'	tie over 8/6/93		
MAIN TO PROP. LINE		TOTAL	82'			
PROP. LINE TO BLDG.						

ENTERS: 429 BRANCHED INTO:
 TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION South side of 429

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
 MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992
 DEPTH: 3 Ft. 0 In. LOCATION West side of S Columbin st

"A" P/S READING .60 TOTAL ANODES 1# 17#0 L.R. #

REMARKS: Note: 79' of 3/4" CW service to over to new main with 3' of 3/4" Plastic pipe
 The .6 PS Reading was taken before 1st Anode Installed
 The 1.40 PS Reading was taken After Anode Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.40
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY