

LOCATION 430 S Columbia St

CITY GASTONIA

BETWEEN Maple

STREET &

5th Ave

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PEW Plastic	49' 23'	Tie over 8/6/93		
MAIN TO PROP. LINE		TOTAL	72'			
PROP. LINE TO BLDG.						

ENTERS: 430

BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION North side of 430

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992


DEPTH: 3 Ft. 0 In. LOCATION West side of S Columbia

"A" P/S READING .60 TOTAL ANODES 1* 17* 0 L.R. #

REMARKS: 49' of 3/4" PEW Service, tied to new main with 23' of 3/4" Plastic Pipe.

Note: The .60 PS Reading was taken before 1st Anode Installed

The .410 PS Reading was taken After Anode Installed



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.0
P/S Pipeline Lead - White Existing Main	E	