

LOCATION 606 S. Columbia St CITY Columbia  
BETWEEN 6th STREET & 5th STREET

	SIZE	TYPE	LENGTH	INSTALLED	<del>RETIRED</del>	<del>RENEWED</del>
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>22'</u>		<u>Tied over</u>	<u>52' of ext</u>
MAIN TO PROP. LINE					<u>3/4" to EXT. 2" plastic</u>	
PROP. LINE TO BLDG.					<u>MAN</u>	<u>8-14-93</u>

ENTERS: 606 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 11' W of Col Columbia

132' S of Col 5th  
PRESSURE TEST: @ 100 psi For 14 Hrs. By ESR 12/1/01


MAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION    

"A" P/S READING P TOTAL ANODES 1# 1 17#     L.R. #    

REMARKS:

Tied wire tied at man



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY