

LOCATION 612 S. Columbia St. CITY BASTONIA  
BETWEEN 5th Ave STREET & 6th Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>31'</u>	<u>8-7-93</u>	<u>Tied over 43'</u>	
MAIN TO PROP. LINE					<u>Existing</u>	<u>3/4 C&amp;W.</u>
PROP. LINE TO BLDG.						

ENTERS: 612 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 175' N of C of E. 6th Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 11' W of C of Columbia Ave.

"A" P/S READING P. TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:

Bare Main Replacement  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser 1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY