


LOCATION	116 Colvard Dr			CITY	Castro		
BETWEEN	Beaky Rd.		STREET @	Dead End		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG.	3/4'	P	95'	6-1-95			
MAIN TO PROP. LINE	3/4'	P	10'				
PROP. LINE TO BLDG.	3/4'	P	85'				
ENTERS: 116 BRANCHED INTO:							
TAP SIZE:	1/2	PRESSURE	60 P.S.I.	INCHES W.C.	LOCATION 421' N. of center of Beaky Rd.		
PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSLER							
MAIN-SIZE	2"	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1990	
DEPTH:	Ft.	In.	LOCATION 12' N. of center of Colvard Dr.				
"A" P/S READING	P		TOTAL ANODES 1# 0 17# 0	L.R. # 242202			

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY