

LOCATION: 1206 Congress St. CITY Gastonia  
BETWEEN Ruby St. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>98'</u>	<u>5-4-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>38'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>60'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE 1/4 PRESSURE 60 PSI INCHES W.C. LOCATION 14' North of

Congress St 456' East of Ruby St.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard


MAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC      YEAR INSTALLED 1983

DEPTH 3 FT 6 N LOCATION 14' North of Congress St.

"A" P/S READING 16.4 TOTAL ANODES 1# 17# LR #     

REMARKS

New Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0. Rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	