

LOCATION 1903 CONNEMARA CT CITY GASTONIA  
BETWEEN LOCKNESS DR. STREET & CULDEESAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>59'</u>	<u>2-26-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>PLASTIC</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>53'</u>			


ENTERS: 1903 CONNEMARA CT. BRANCHED INTO: 0  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION EAST SIDE OF 1903

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1987

DEPTH: 3' FT. 0" IN. LOCATION SOUTH SIDE OF CONNEMARA CT

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. # 093018

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY