

LOCATION 145 Cooks Lake Rd. CITY GASTONIA
BETWEEN Beaty Rd. STREET & Keltic Meadows Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>250'</u>	<u>9-9-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>195'</u>			

ENTERS: 145 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 855' N of C of Keltic Meadows Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 15' W of C of Cooks Lake Rd.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 444 406

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u> <u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY