

LOCATION 102 Country Ln. CITY GASTONIA
BETWEEN Country Ln. STREET & Cameron Pointe STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>134'</u>	<u>1-14-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>70'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>64'</u>			

ENTERS: 102 BRANCHED INTO: 0

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 242' S of C of Cameron Pointe


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 16' E of C of S. New Hope Rd.

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 000136

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY