

LOCATION 1841 COUNTRY CLUB RD. CITY GASTONIA
BETWEEN RIDGE LANE STREET & NEW HOPE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>140'</u>	<u>11.13.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>110'</u>			

ENTERS 1841 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION W. side of 1841

PRESSURE TEST @ 150 PSI FOR 1/4 HRS BY GK
MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1964
DEPTH 3 FT IN LOCATION N. side of Country Club Rd

"A" P/S READING 1.0 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	