

LOCATION 3504 Coontoy Club Dr. CITY Castroville
BETWEEN Kendrick Rd STREET & Clubview STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>Relabeled</u>		
MAIN TO PROP. LINE				<u>6-29-95</u>		
PROP. LINE TO BLDG.						

ENTERS: 3504 BRANCHED INTO: 0

TAP SIZE: _____ PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP 6-5-95

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1973

DEPTH: 1 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>2.8</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY