

LOCATION 3521 Country Club Dr.

CITY GASTONIA

BETWEEN Kendrick Rd.

STREET & Sherwood Circle

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	97'	10-20-94		
MAIN TO PROP. LINE	3/4	Plastic	7'			
PROP. LINE TO BLDG.	3/4	Plastic	90'			

ENTERS: 3521

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 335' E of C of Kendrick Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1958

DEPTH: 3 Ft. 0 In. LOCATION 20' N of C of Country Club Dr.

"A" P/S READING .85 TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY