

LOCATION 3630 Country Club Dr. CITY St. Louis

BETWEEN Kendrick Rd STREET & Shannon Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>80</u>	<u>6-10-84</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>75</u>			

ENTERS: 3630 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Inside house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Jenett

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL / PLASTIC \_\_\_\_\_ YEAR INSTALLED 1958

DEPTH: 2 Ft. 6 In. LOCATION 15' E of Cyl

"A" P/S READING 1.0 TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 00242140

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY