

LOCATION 4833 Country Meadows

CITY Gastonia

BETWEEN Hidden meadows

STREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	90'	12-22-93		
MAIN TO PROP. LINE	3/4	P	20'			
PROP. LINE TO BLDG.	3/4	P	70'			

ENTERS: 4833

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION N. Side of 4833


PRESSURE TEST: @ 100 psi For 14 Hrs. By BC

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1984

DEPTH: 3 Ft. In. LOCATION 30 E of C of Country meadows

"A" P/S READING plastic TOTAL ANODES 1* — 17* — L.R. # 506 532

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY