

LOCATION 258 Court Dr. CITY GASTONIA

BETWEEN Employee Dr. STREET & Co. Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>208'</u>	<u>8-19-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>86'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>122'</u>			

ENTERS: 258 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 47' S. of center of

Court Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HURSTHILL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1972

DEPTH: 4 FT. 0 IN. LOCATION 25' W. of center of Employee Dr.

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 L.R. # 2008830

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY