

LOCATION 2260 Court DrCITY GastoniaBETWEEN New HopeSTREET & X Ray

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	88	4-11-95		
MAIN TO PROP. LINE	"	"	73'			
PROP. LINE TO BLDG.	"	"	15'			

ENTERS: 2260BRANCHED INTO: 0TAP SIZE: 1/2

PRESSURE


60

P.S.I.

INCHES W.C.

LOCATION 569 E of C ofNew HopePRESSURE TEST: @ 160 psi For 1/4 Hrs. By BLMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC ✓YEAR INSTALLED 1995DEPTH: 3 Ft. In.LOCATION 29' S of C of Court"A" P/S READING PlasticTOTAL ANODES 1# - 17# -L.R. # 159777

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY