

LOCATION 2505 Court Dr. (GASTON County DETOX Center) CITY GASTONIA
BETWEEN COX RD STREET & N. NEW HOPE RD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	2"	PLASTIC	92'	8-31-94		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2505 BRANCHED INTO:

TAP SIZE: 2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 18.7' S. of center of

Driveway


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffman

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 90' W. of center of PARKING LOT ENTRANCE

"A" P/S READING TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS: 2" ANODELESS RISER



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY