

LOCATION 2525-A Court Dr. CITY Salina

BETWEEN	STREET &	STREET				
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>128</u>	<u>12-9-91</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>"</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>128</u>			

ENTERS: 2525 A BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ PSI _____ INCHES W C LOCATION North of Washburn


PRESSURE TEST: @ 100 psi For 1/4 Hrs By J. Bane

MAIN - SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1972

DEPTH: 2 Ft. 6 In. LOCATION 24' W 10425

"A" P/S READING 1.30 TOTAL ANODES 1 # _____ 17 # _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

SERVICE LOCATION RECORD

K	LOC	ACCT	SUB	WORK ORDER NO	CITY NO	KEY NO	GRID NO	CP NO	PROJECT NO.
1	100	38410	2001	059525	700	56	AM-34	357	

