

LOCATION 2509 Cove Creek Dr. CITY Gastonia

BETWEEN Frambrook Dr. STREET & Derrydown. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	73'	9-20-96		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	68'			

ENTERS: 2509 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 318' SE of center of Frambrook Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huttelbeck

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION 14' SW. of center of Cove Creek Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 508347

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY