

LOCATION 2518 Cove Creek Dr. CITY GASTON

BETWEEN Farmbrook Dr. STREET & Derry Down. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>111'</u>	<u>9-6-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>81'</u>			

ENTERS: 2518 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 211' N.W. of center of Derry Down.


PRESSURE TEST: @ 100 psi For 44 Hrs. By S. Hefford

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 Ft. 0 In. LOCATION 15' NE of center of Cove Creek Dr.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 446640

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY