

LOCATION 315 Cox dr

CITY GASTONIA

BETWEEN MT. HEbron

STREET & MAPLE

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED ^{Relocated}	RENEWED
MAIN TO BLDG.	3/4	P	2'		10-21-93	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 315

BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 324' N. of C of Cox dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S R	P.
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY