

LOCATION 400 GOX RD

CITY GASTONIA

BETWEEN I-85

STREET &amp; HWY-74

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	42'	11-30-92		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 400 - mant Bldg BRANCHED INTO: —

TAP SIZE: 3/4 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 41 W OF EAST WALL


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

SER MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 19

DEPTH: 1 Ft. 6 In. LOCATION 8' N OF N WALL

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-RISER
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY