

LOCATION 545 COX RD CITY CASTONIA
BETWEEN ABERDEEN BLVD STREET & PEMBROKE RD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>60'</u>	<u>10-30-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>54'</u>			

ENTERS: 545 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI 0 INCHES W.C. LOCATION 273' W of E of COX RD


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R.L

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1977

DEPTH: 2' FT. 0 IN. LOCATION 26' S of E of ABERDEEN BLVD

"A" P/S READING • 85 TOTAL ANODES 1# 0 17# 0 L.R. # 0736241

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Rise</u>	