

LOCATION 561 Cox RdCITY GASTONIABETWEEN AberdeenSTREET & Pembroke

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>75'</u>	<u>9-27-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>65'</u>			

ENTERS: 561

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 35' West of
Cox RdPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 12" C.I. BARE STEEL COATED STEEL X PLASTIC YEAR INSTALLED 1988DEPTH: 7' Ft. 6 In. LOCATION 155' N of Pembroke"A" P/S READING .75 TOTAL ANODES 1* 17* 2 L.R. # 403 293

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>P-RISER</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY