

LOCATION 584 Cox Rd. CITY Gastonia
BETWEEN Aberdeen Blvd STREET & ~~2005~~ Pembroke Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>54'</u>	<u>4-17-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>50'</u>			

ENTERS 584 BRANCHED INTO:
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 214' E. of center of
Cox Rd.

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.H.
MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995
DEPTH. 3 FT 0 IN LOCATION 211 S. of center of Aberdeen Blvd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 300184

REMARKS:

	Test Station	
	Lead	Volts
Reading & Location		
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

