

LOCATION

610 A Cox Rd.

CITY

Canton

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/4"	P	282'	8-24-95		
MAIN TO PROP. LINE	3 1/4"	P	50'			
PROP. LINE TO BLDG.	3 1/4"	P	232'			

ENTERS:

610 A

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

243' E. of center of

Cox Rd.

PRESSURE TEST:

@

100

psi

For

1/4

Hrs.

By

S. Huffstetler

MAIN-SIZE

4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1995

DEPTH:

3 Ft.

0 In.

LOCATION

20' S. of center of Aberdeen Blvd.

"A" P/S READING

P


TOTAL ANODES 1*

17*

L.R. #

421013

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E