

LOCATION 631 Cox RDCITY GASTONIABETWEEN LanierSTREET & Hwy 7

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>109'</u>	<u>10-8-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>		<u>TIED over</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>		<u>140' 3/4" P</u>		

ENTERS: 631

BRANCHED INTO:

TAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 23' south ofLanierPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL A PLASTIC _____ YEAR INSTALLED 19661988DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING .7TOTAL ANODES 1* 0 17* _____

L.R. # _____

REMARKS: 2 - 17 # ANODES INSTALLED ON MAIN ON WO# 96100

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY