

LOCATION CRAMER woods DR CITY Gastonia
BETWEEN CRAMER woods DR STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	140'	7-13-00		
MAIN TO PROP LINE	1"	1"	95'			
PROP LINE TO BLDG	1"	1"	95'			

ENTERS _____ BRANCHED INTO _____
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 20' W. of C of


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP old Town LA

MAIN-SIZE 2 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	