

LOCATION 5026 Cramer Woods Dr. CITY GASTONIA
BETWEEN Summerell Ave. STREET & S. New Hope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>27'</u>	<u>1-18-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>22'</u>			

ENTERS 5026 BRANCHED INTO 5030
TAP SIZE 3/4" PRESSURE 100 PSI _____ INCHES W.C. LOCATION 83' N. of center of Cramer Woods Dr.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.

PIPE SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 2 FT 0 IN LOCATION 105' E. of center of Summerell Ave.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 11575

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	