

LOCATION 5038 Crane Woods Dr CITY GASTONIA

BETWEEN Simmons Ave STREET & Featherstone Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	76'	3-6-01		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	66'			

ENTERS 5038 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 107' SW. of cor. of Simmons Ave.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY SLH

MAIN-SIZE 8" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 16' N. of center of Crane Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 163389

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	