

LOCATION 5048 Cramer Woods Dr. CITY Easton, MA
 BETWEEN Summerell Ave. STREET & Featherstone Ct. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 5/8" | P | 78' | 1-25-02 | | |
| MAIN TO PROP LINE | 5/8" | P | 6' | " | | |
| PROP LINE TO BLDG | 5/8" | P | 72' | " | | |

ENTERS 5048 BRANCHED INTO 0
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 192' north


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
1/2 cent of Featherstone Ct.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 18' west of center of Cramer Woods Dr.

"A" P/S READING 1114 TOTAL ANODES 1# 0 17# 0 LR # 00013941

REMARKS New Plastic service



| Test Station | | |
|--|------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | <u>plastic</u> |
| P/S Pipeline Lead - White Existing Main | E | <u>pipe</u> |