

LOCATION S057 Cramer Woods Dr. CITY GASTONIA
BETWEEN Featherstone Ct STREET & Old Stone Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	126'	7-12-00		
MAIN TO PROP LINE	3/4"	P	6'			
PROP LINE TO BLDG	3/4"	P	120'			

ENTERS S057 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 121' S. of center of Cramer Woods Dr


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 19' W. of center of Featherstone Ct

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 LR # 587094

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	