

LOCATION 5060 CRAMEL WOODS DR CITY GASTONIA
BETWEEN FEATHERSTONE STREET & CU1-20-50C STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>84'</u>	<u>10.3.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>80'</u>			

ENTERS 5060 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION N/E side of 5060

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GL
MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 2000
DEPTH 3 FT IN LOCATION N. side of CRAMEL WOODS DR

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	