

LOCATION 5070 Crane Woods Dr CITY CASTON, A  
BETWEEN OLD TOWN LN. STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>78'</u>	<u>7-5-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>71'</u>			

ENTERS 5070 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 100 PSI INCHES W C LOCATION 130' W. of center of  
OLD TOWN LN.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.C.H.

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 18' N. of center of Crane Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 545334

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	