

LOCATION 5087 Cramer Woods Dr. CITY Gastonia

BETWEEN OLD TOWN Ln. STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>2 1/4"</u>	<u>P</u>	<u>80'</u>	<u>5-25-00</u>		
MAIN TO PROP LINE	<u>2 1/4"</u>	<u>P</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3 1/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS 5087 BRANCHED INTO

TAP SIZE 2 1/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 507' S.W. of center of
OLD TOWN Ln.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.H.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 29' S. of center of Cramer Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L R # 434888

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	