

LOCATION 3702 Crawford Ave.

CITY GASTONIA

BETWEEN NASSAU PL.

STREET &amp; DAVIS PARK Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	82'	11-17-95		
MAIN TO PROP. LINE	3/4	Plastic	8'			
PROP. LINE TO BLDG.	3/4	Plastic	74'			

ENTERS: 3702

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 90' S of C of NASSAU PL.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1968

DEPTH: 3 Ft. 0 In. LOCATION 8' E of C of Crawford Ave.

"A" P/S READING 1.2 TOTAL ANODES 1\* 17\* L.R. # 582148

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY