

LOCATION 4228 Creek Ridge Dr CITY Gastonia  
BETWEEN Hollow Pine Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>109'</u>	<u>3-27-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>42'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>67'</u>			

ENTERS 4228 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 49' S. of center of Hollow Pine Ct.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.  
MAIN SIZE 4 C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2000  
DEPTH 3 FT 0 IN LOCATION 17' W. of center of Creek Ridge Dr.

"A" P/S READING 2 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

