

LOCATION 4236 Creek Ridge Dr. CITY CASPER

BETWEEN Hollow Pine Cr STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	26'	3-27-01		
MAIN TO PROP LINE	3/4"	P	10'			
PROP LINE TO BLDG	3/4"	P	16'			

ENTERS 4236 BRANCHED INTO _____

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W/C LOCATION 53 S. of center of

Hollow Pine Cr

PRESSURE TEST @ 100 PSI FOR 14 HRS BY ST

MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 2 FT 0 IN LOCATION 73' E of center of Creek Ridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS _____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

