

LOCATION 4264 Creek Ridge Dr. CITY Custar, OH
BETWEEN Timberwood Ct STREET & Hollow Pine STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	60'	1-18-02		
MAIN TO PROP LINE	5/8"	P	8'	"		
PROP LINE TO BLDG	3/8"	P	60'	"		

ENTERS 4264 BRANCHED INTO E

TAP SIZE 3/4" PRESSURE 60 PSI 60 INCHES WC LOCATION 30.6' west of

center of Timberwood Ct.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY D. Woody

MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 3' FT 0" IN LOCATION 19' south of center of Creek Ridge Ct

"A" P/S READING 1112 TOTAL ANODES 1# 1 17# 1 LR # 0000 8339

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	1112