


LOCATION 4276 Creek Ridge Dr CITY Greenville
 BETWEEN Timberwood ct. STREET & Hollow Pine ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	99'	11-9-01		
MAIN TO PROP LINE	5/8"	P	42'	"		
PROP LINE TO BLDG	5/8"	P	57'	"		

 ENTERS 4276 BRANCHED INTO 0
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W/C LOCATION 243' west
of center of Timberwood ct.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
 MAIN-SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001
 DEPTH 3 FT 0" IN LOCATION 12' south of center of Creek Ridge Rd.
 "A" P/S READING 1114 TOTAL ANODES 1# 0 17# 0 LR # 60119802
 REMARKS NEW 5/8" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	11.5m