

LOCATION 1314 Creekview Dr CITY Gastonia

BETWEEN Candlewood Dr STREET & Shady Oak Trl. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>101'</u>	<u>2-5-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>61'</u>			

ENTERS: 1314 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 106' NE. of center of

Candlewood Dr


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION 17' S. of center of Creekview Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 67439

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY