

LOCATION 1201 Crescent Ave. CITY GASTONIA

BETWEEN Dale St STREET & S. York Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>66'</u>		<u>2-24-98</u>	
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>		<u>Retired</u>	<u>77' 3/4"</u>
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>56'</u>			<u>NEW SERVICE</u>

ENTERS: 1201 BRANCHED INTO:

TAP SIZE. 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 50' W. of center of

Crescent Ave


PRESSURE TEST: @ 100 PSI FOR 114 HRS. BY S. Hurt & Sellen

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 18' S. of center of Dale St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY