

LOCATION 1216 Crescent Ave CITY Gastonia
BETWEEN S. York Rd STREET & Dale Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>12'</u>	<u>Tied over</u>	<u>3/4 Plastic</u>	<u>Service</u>
MAIN TO PROP. LINE				<u>to 2"</u>	<u>Plastic man</u>	
PROP. LINE TO BLDG.					<u>2-24-98</u>	

ENTERS: 1216 BRANCHED INTO: —
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1987
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING Pl. TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>P.S.</u>	<u>Plade</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY