

LOCATION 2515 Crescent Ln. CITY Easton
BETWEEN Carroll STREET & Jupiter STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>92'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			<u>6/2/95</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>52'</u>			

ENTERS: 2515 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 44 Hrs. By EP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1961

DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY