

LOCATION 739 PRESTWOOD AVE CITY EAST

BETWEEN FOREST DR. STREET & TANGLEWOOD DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>101'</u>			<u>2-12-97</u>
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>99'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 'Front @ OF

FOREST DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY AKJ

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH. 3 FT 0 IN LOCATION South side of PRESTWOOD AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY