

LOCATION 1409 Crimson Ct CITY Gastonia
BETWEEN Newport Ct. STREET & Timberwoods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>102</u>	<u>12-20-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>6'</u>	<u>11</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>96'</u>	<u>11</u>		

ENTERS 4409 BRANCHED INTO Ø
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 317' West of center of Timberwoods Dr.

PRESSURE TEST @ 100 PSI FOR 114 HRS BY D. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2008

DEPTH 3' FT 0" IN LOCATION 35' South of center of Crimson Ct.

"A" P/S READING 11H TOTAL ANODES 1# Ø 17# Ø LR # 369676

REMARKS New plastic service

