

LOCATION 4418 Crimson Ct. CITY Gastonia  
BEETWEEN Timberwood Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>81'</u>	<u>10-10-02</u>		
MAIN TO PROP LINE	<u>5/8</u>	<u>P</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>P</u>	<u>75'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 43' North of  
Crimson Ct. & 361' west of Timberwood Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard


MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 3 FT 6 IN LOCATION 43' North of Crimson Ct.

"A" P/S READING Plastic TOTAL ANODES 1# 17# LR #

REMARKS

New 5/8" plastic serv.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p-Rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	