

LOCATION 116 + 107 Hazelwood + 4320 Cross RidgeCITY Spartanburg

BETWEEN

STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	366	9-14-89		
MAIN TO PROP. LINE	3/4	"	83			
PROP. LINE TO BLDG.	3/4	"	283			

ENTERS: 116BRANCHED INTO: 107 Hazelwood + 4320 Cross Ridge

TAP SIZE:


PRESSURE

P.S.I.

INCHES W.C.

LOCATION SW side of housePRESSURE TEST: @ 100 psi For 1/4 Hrs. By BorrettMAIN-SIZE 2 C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1989DEPTH: 2 Ft. 6 In. LOCATION 27' W of C of St."A" P/S READING      TOTAL ANODES 1\*      17\*      L.R. #     

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P/S Pipeline Lead - White  
Existing Main

E