

LOCATION 3609 Crawlers View Dr. CITY Boston MA
BETWEEN Tanner Ct. STREET & Hope Haven Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>70'</u>	<u>1-3-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>14'</u>	<u>"</u>		

ENTERS 3609 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 143' south -


PRESSURE TEST @ 110 PSI FOR 1/4 HRS BY J. W. W. W. of center of Crawlers View Dr.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 2003

DEPTH 3' FT 0" IN LOCATION 14' East of center of Crawlers View Dr.

"A" P/S READING 7.14 TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS new plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	